

Certificate of Acknowledgment

NORMAN NOBLE, INC.

ISO Class 7 @ 0.5 µm

Gown Room

Meets requirements as tested in accordance with specifications and guidelines of the International Organization for Standardization ISO 14644-1:2015(E) and ISO 14644-3:2005(E) §B.1. This certificate will expire one year from the date of verification. Details are outlined in the corresponding test report #2204A135.

Airborne Non-Viable Particle Measurement

Pass

Airflow Measurement

N/A

Room Pressurization Measurement

N/A

HEPA Filter Installation Leak Test

Pass

Airborne Viable Particle Measurement

Not Tested

Bacterial Fungal

Surface Viable Particle Measurement

Not Tested

Bacterial Fungal

Julie Weidemann

4/12/2022



Quality Testing Services by Quality People

37709 Schoolcraft Road, Livonia, MI 48150
ph: (734) 522-1533 • fx: (734) 522-1534
catestinginc.com • info@catestinginc.com

Certificate of Acknowledgment

NORMAN NOBLE, INC.

ISO Class 7 @ 0.5 μm

Walk-in Pass Thru

Meets requirements as tested in accordance with specifications and guidelines of the International Organization for Standardization ISO 14644-1:2015(E) and ISO 14644-3:2005(E) §B.1. This certificate will expire one year from the date of verification. Details are outlined in the corresponding test report #2204A135.

Airborne Non-Viable Particle Measurement

Pass

Airflow Measurement

N/A

Room Pressurization Measurement

N/A

HEPA Filter Installation Leak Test

Pass

Airborne Viable Particle Measurement

Not Tested

Bacterial Fungal

Surface Viable Particle Measurement

Not Tested

Bacterial Fungal

Julie Weidemann

4/12/2022



Quality Testing Services by Quality People

37709 Schoolcraft Road, Livonia, MI 48150
ph: (734) 522-1533 • fx: (734) 522-1534
catestinginc.com • info@catestinginc.com

Certificate of Acknowledgment

NORMAN NOBLE, INC.

ISO Class 7 @ 0.5 μ m

Cleanroom

Meets requirements as tested in accordance with specifications and guidelines of the International Organization for Standardization ISO 14644-1:2015(E) and ISO 14644-3:2005(E) §B.1. This certificate will expire one year from the date of verification. Details are outlined in the corresponding test report #2204A135.

Airborne Non-Viable Particle Measurement

Pass

Airflow Measurement

N/A

Room Pressurization Measurement

N/A

HEPA Filter Installation Leak Test

Pass

Airborne Viable Particle Measurement

Not Tested

Bacterial Fungal

Surface Viable Particle Measurement

Not Tested

Bacterial Fungal

Julie Weidemann

4/12/2022



Quality Testing Services by Quality People

37709 Schoolcraft Road, Livonia, MI 48150
ph: (734) 522-1533 • fx: (734) 522-1534
catestinginc.com • info@catestinginc.com