

# Certificate of Acknowledgment

NORMAN NOBLE, INC.

ISO Class 7 @ 0.5 µm

Gown Room

Meets requirements as tested in accordance with specifications and guidelines of the International Organization for Standardization ISO 14644-1:2015(E) and ISO 14644-3:2005(E) §B.1. This certificate will expire one year from the date of verification. Details are outlined in the corresponding test report #2204A135.

**Airborne Non-Viable Particle Measurement**

Pass

**Airflow Measurement**

N/A

**Room Pressurization Measurement**

N/A

**HEPA Filter Installation Leak Test**

Pass

**Airborne Viable Particle Measurement**

Not Tested

Bacterial  Fungal

**Surface Viable Particle Measurement**

Not Tested

Bacterial  Fungal



Julie Weidemann

4/12/2022



Quality Testing Services by Quality People

37709 Schoolcraft Road, Livonia, MI 48150  
ph: (734) 522-1533 • fx: (734) 522-1534  
catestinginc.com • info@catestinginc.com

# Certificate of Acknowledgment

NORMAN NOBLE, INC.

ISO Class 7 @ 0.5 µm

Walk-in Pass Thru

Meets requirements as tested in accordance with specifications and guidelines of the International Organization for Standardization ISO 14644-1:2015(E) and ISO 14644-3:2005(E) §B.1. This certificate will expire one year from the date of verification. Details are outlined in the corresponding test report #2204A135.

**Airborne Non-Viable Particle Measurement**

Pass

**Airflow Measurement**

N/A

**Room Pressurization Measurement**

N/A

**HEPA Filter Installation Leak Test**

Pass

**Airborne Viable Particle Measurement**

Not Tested

Bacterial  Fungal

**Surface Viable Particle Measurement**

Not Tested

Bacterial  Fungal

Julie Weidemann

4/12/2022



Quality Testing Services by Quality People

37709 Schoolcraft Road, Livonia, MI 48150  
ph: (734) 522-1533 • fx: (734) 522-1534  
catestinginc.com • info@catestinginc.com

# Certificate of Acknowledgment

NORMAN NOBLE, INC.

ISO Class 7 @ 0.5 µm

Cleanroom

Meets requirements as tested in accordance with specifications and guidelines of the International Organization for Standardization ISO 14644-1:2015(E) and ISO 14644-3:2005(E) §B.1. This certificate will expire one year from the date of verification. Details are outlined in the corresponding test report #2204A135.

**Airborne Non-Viable Particle Measurement**

Pass

**Airflow Measurement**

N/A

**Room Pressurization Measurement**

N/A

**HEPA Filter Installation Leak Test**

Pass

**Airborne Viable Particle Measurement**

Not Tested

Bacterial  Fungal

**Surface Viable Particle Measurement**

Not Tested

Bacterial  Fungal

Julie Weidemann

4/12/2022



Quality Testing Services by Quality People

37709 Schoolcraft Road, Livonia, MI 48150  
ph: (734) 522-1533 • fx: (734) 522-1534  
catestinginc.com • info@catestinginc.com